

Doc. nr. <b>9124581</b>	Rev. <b>A</b>	Registration form. <b>Settings – 165 °F</b>	
----------------------------	------------------	--	--

MD25-5 with FD USA	MC40 H with FD + SB USA
MD48-4 with FD USA	MD40-5 with FD USA
MD48-5 with FD USA	MDS 34-2 with FD USA

## Controller: Eliwell ICPlus 902

**Note:** Use tool **STICK 2** for inserting parameters and only change **orange arced parameters** manually!

**Note:** When adjusting parameters manually change “**dro**” first if needed.

User parameters:

SP1	Temperature set point	<b>165</b>	°F
dF1	Differential	<u>2</u>	K
HS1	Max set point limitation	<u>210</u>	°F
LS1	Min set point limitation	<u>32</u>	°F
LoC	Keypad lock n(0)=lock disabled y(1)=lock enabled	<b>n</b>	
ndt	Display with decimal point, n(0)=no y(1)= yes	<b>y</b>	
CA1	Display offset	<b>-20.7</b>	°F
H00	Sensor type, 0 = ptc, 1 = ntc	<u>0</u>	

Installer parameters:

rE1	HC1	Cold “C(0)” or hot “H(1)” operation	<b>H</b>	
	HA1	Max temp alarm	<u>212</u>	°F
diS	dro	Unit of measurement (0 =°C 1 =°F)	<u>1</u>	